



OFFICE OF THE DEPUTY FIRE OFFICER,  
KORAPUT CIRCLE, KORAPUT.

\*\*\*\*\*

FORM -V

FIRE SAFETY CERTIFICATE

(See rule -13(3) of the Odisha Fire Prevention and Fire Safety Rules, 2017)

File No. 15/2020 (FP)/KPT CRL, Koraput. Dtd: 04.03.2020.

Certificate No: -56/KPT CRL/2020, Dtd:27.10.2020.

This Certificate is valid up to Two Years from the date of issue.

(Apply for renewal at least three months before expiry)

\*\*\*\*\*

Certified that the school building (Four Blocks) of Swami Vivekananda Banabharati Bidyapitha, Koraput, Dist- Koraput is situated over plot No. 19 & 20, Khata No:- 31 Mouza- Koraput Nagar, Tahasil- Koraput, Dist- Koraput consisting of total Four number of Block was inspected by officers of the Fire Service on 26.10.2020 in presence of Sri P.Madhab Rao, Clerk and it has been found to comply with the Fire Prevention and Safety requirements in accordance with the Odisha Fire Prevention and Fire Safety Rules ,2017 and that its various floors are fit for occupancy or usage as noted hereunder against each subject to compliance to the conditions as prescribed herein below:

1. G+1 floors (Block 01) =	-----Usage-----	Educational
2. G+2 floors (Block 02) =	-----Usage-----	Educational
3. G floor (Block 03) =	-----Usage-----	Educational (Nursery)
4. G floor (Block 04) =	-----Usage-----	Educational

CONDITIONS:-

1. Fire prevention and safety measures and appliances, availability of water supplies and means of access thereto etc provide in the premises, should be maintained by the occupier in best repairs and efficient working condition at all times for use by the occupants or the members of the Fire Service or both in the event of outbreak of fire.
2. The set-backs, driveways, entrance gates, exits, and escape ways should not be changed, obstructed or modified in any way.
3. The occupiers shall train all staff and occupants periodically to make them well conversant in use and operation of the fire prevention and safety measures.
4. Fire drills/rehearsals should be organized at least once in six months by involving Local Fire Station.
5. Photocopies of this certificate should be framed and displayed at all conspicuous places in all lobbies/corridors in all floors of all towers/blocks of building / premises.

By order of the Director of Fire Service

Signature with Seal

27/10/20


(Rengadhar Acharya)  
Deputy Fire Officer  
Dy. Fire Officer  
Koraput Circle  
Koraput Circle Koraput

Name and Designation of Issuing Officer:

Submitted to the Principal, Swami Vivekananda Banabharati Bidyapitha, Koraput, Dist- Koraput a/w additional conditions as mentioned below for information and necessary action.

Additional Views/ Conditions

1. FSC is being issued after Govt. of Odisha, Home Deptt Notification No. 28550/CD, Bhubaneswar, Dtd 28.08.2020 (i.e one time relaxation scheme). One time relaxation is given against width of stairways in Block-I&II and open space in Block-III & IV.
2. Plan of the afore-said school building should be approved by the competent building plan approving authority at an early.
3. Failure of proper maintenance & non-functional of Fire Fighting gadgets at the time of emergency shall be the responsibility of the occupier/management.
4. Good housekeeping both inside and outside should be maintained throughout and there must not be any laxity in this regards.
5. The management shall provide any additional fire safety requirements, in future, if issued from time to time by this department.
6. All electrical installations must be periodically checked & tested by competent electrical engineers. All loose electrical wiring if any shall be replaced immediately. Electrical safety audit should be carried out at regular interval as per Indian Electrical Rules.
7. No Smoking Zone (while applicable in office, class room etc) should be enforced rigidly.
8. Trained staff in dealing with fire fighting extinguishers/ appliances/ Evacuation procedure should be engaged.

  
27/10/20  
Dy. Fire Officer  
Koraput Circle, Koraput  
Koraput